United States Environmental Protection Agency (EPA)
Region 2
290 Broadway
New York, NY 10007-1866

Underground Storage Tank (UST) Inspection Form

INSPECTOR NAME(S): Paul Sucker DATE: 2/1/13

SIC CODE: ICIS #:

I. Location of Tank(s) ☐ Tribal

Facility Name: TAG GASOLINE
Street Address: 653 Hempstead Turnpike
City: Elmont State: NY Zip Code: 11003
County: Nassau
Phone Number: 516 328 1840 Fax Number:
Contact Person(s): Julia Tsygankova

II. Ownership of Tank(s) ☐ same as location (I.)

Owner Name: Black Reality INC.
Street Address: Same
City: State: Zip Code:
County: Nassau
Phone Number: Fax Number:
Contact Person(s): ~~Rachel Yetim~~ Rachel Ann Yetim

IIA. Ownership of Other Facilities

☐Do you own other UST Facilities **Yes / No**

If Yes, How many Facilities _____ How many USTs _____

III. Notification

☐ Notification to implementing agency; name NCDO FM : 2011TR00114 Exp: 11/31/16 Issued 11/26/11
State Facility ID #

IV. Financial Responsibility

☐ State Fund _____ ☐ Private Insurance: Insurer/Policy #_____
☐ Guarantee ☐ Surety Bond ☐ Letter of Credit
☐ Local Government ☐ Self Insured ☐ **Not Required** (Federal & State government, hazardous substance USTs)

V. Release History N/A ☐

☐ To your knowledge, are there any public or private Drinking Water Wells in the vicinity ? **Yes / No**

☐ Evidence of release or spills at facility ☐ Greater than 25 gallons (estimate)
☐ **Releases reported to implementing agency; if so, date(s)** _____ [280.53]
☐ Release confirmed; when and how _____
☐ Initial abatement measures and site characterization ☐ Free product removal
☐ Soil or ground water contamination ☐ Corrective action plan submitted
☐ Remediation ongoing ☐ Remediation completed, no further action; date(s)_____

Notes: Julia says that Rachel Ann owns TAG Gasoline as well as Black Realty.

 Init/Date 2/1/13 11/04/2010

VI. Tank Information	Tank No.	10664	10661				
Tank presently in use		Y	X				
If not, date last used	(see Section XII)						
If empty, verify 1" or less left	(see Section XII)						
Capacity of Tank (gal)		8K	6K				
Substance Stored		Reg	Super				
M/Y Tank installed / Upgraded		12/04/85	12/04/85				
Tank Construction: Bare steel, Sti-P3, Retrofitted sacrificial anode, Impressed Current, Composite, FRP, Interior lining, Vaulted, Double-walled (DW)		SW FRP	→				
Spill Prevention		✓	✓				
Overfill Prevention (specify type)		Shut	Off →				
Special Configuration: Compartmentalized, Manifolded							

VII. Piping Information							
Piping Type: Pressure, Suction		✓	✓				
Piping Construction: Bare steel, Sacrificial Anode, Impressed Current, Flex, FRP, Double-walled (DW)		Steel	→				

Tank and Piping Notes:

Piping observed to be metal in both sumps - tested with magnet - Piping went underground. Pumps themselves are still in dirt filled pits - rusting.

VIII. Cathodic Protection		N/A ☐ ?					
Integrity Assessment conducted prior to upgrade							
Interior Lining:	Interior lining inspected						
Impressed Current	CP Test records						
	Rectifier inspection records						
Sacrifical Anode:	CP test records						

CP Notes:

Requested corrosion tests - but none available

Init/Date AF 2/11/13

	Tank No.	664	666				
IX. UST system used solely by Emergency Power Generator		N	N				

X. Release Detection N/A ☐

Tank RD Methods	ATG						
	Interstitial Monitoring						
	Groundwater Monitoring						
	Vapor Monitoring						
	Inventory Control w/ TTT	Y	Y				
	Manual Tank Gauging						
	Manual Tank Gauging w/ TTT						
	SIR						
12 Months Monitoring Records	*(Must Make Available Last 12 Months For Compliance)*	← Yes →					

Tank RD Notes: (State What Months Records Were Available, Describe Any Failures and Describe What Investigation Occurred Due to Failure)

Inventory Control only method – No other form of RD.
No Tank Tightness test available.

Pressurized Piping RD Methods		N/A ☐					
	Interstitial Monitoring						
	Groundwater Monitoring						
	Vapor Monitoring						
	SIR						
12 Months Monitoring Records							
	Annual Line Tightness Test						
ALLD	Present						
	Annual Test						

Piping RD Notes: (State What Months Records Were Available, Describe Any Failures and Describe What Investigation Occurred Due to Failure)

Requested proof of RD for pipes – none available. No ALLD test.

Init/Date AV 11/13

XI. Repairs N/A ☐

Repaired tanks and piping are tightness tested within 30 days of repair completion	Y ☐ N ☐ Unknown ☐
CP systems are tested/inspected within 6 months of repair of any cathodically protected UST system	Y ☐ N ☐ Unknown ☐
Records of repairs are maintained	Y ☐ N ☐ Unknown ☐

XII. Temporary Closure N/A ☐

CP continues to be maintained	Y ☐ N ☐ Unknown ☐
UST system contains product and release detection is performed	Y ☐ N ☐ Unknown ☐
Cap and secure all lines, pumps, manways	Y ☐ N ☐ Unknown ☐

Notes:

Explained in detail to Julia what Violations there are and what she needs to do to correct them.

SH I wrote her some notes in a notebook and plan to e-mail her info.

Init/Date 11 2/1/13

THE UNITED STATES ENVIRONMENTAL PROTECTION AGENCY (EPA) REGION 2 UST PROGRAM
Ground Water Compliance Section
New York, NY 10007-1866

Inspector Observation Report

Inspection of Underground Storage Tanks (USTs)

☐ No violations observed at the conclusion of this inspection.

☑ The above named facility was inspected by a duly authorized representative of EPA Region 2, and the following are the inspector's observations and/or recommended corrective action(s):

Violations Observed:

Regulatory Citation	Violation Description
§ 280.21(c)	No upgrade of metallic piping to have
§	corrosion protection
§ 280.41(a)	No valid release detection method
§ ~~280.41(b)(1)(i)~~	
§ 280.41(b)(1)(ii)	No release detection for pressurized piping
§ 280.44(a)	No annual automatic line leak detector test
§	
§	

Actions Taken:
☐ Field Citation; # ________ ☐ Additional Information required ☐ On-site request/Due date ________

Comments/Recommendations:

Name of Owner/Operator Representative: Iuliia Tsygankova
(Please print)
[signature]
(Signature)

Other Participants: ________

Name of EPA Inspector/representative Paul Sacker
(Please print)
[signature]
(Signature)
F13670
(Credential Number)

Date of Inspection 2/1/13 Time 10:00 AM/PM

 Init/Date [initials] 2/1/13 11/04/2010

SITE DRAWING

DATE: _____ TIME ON SITE: _____ TIME OFF SITE:

WEATHER:

ENVIRONMENTALLY SENSITIVE AREA : Y ☐ N ☐
If "Yes", please describe:

☐ Pictures

Required Fields to be used for ICIS Only

Compliance Monitoring

Activity: UST Inspection

Inspection Conclusion Data Sheet

1) Did you observe deficiencies (preferred violations) during the on-site inspection?

Deficiencies observed: (Put an **X** for each observed deficiency)

___ Potential failure to complete or submit a notification, report, certification, or manifest

_✓_ Potential failure to follow or develop a required management practice or procedure

_✓_ Potential failure to maintain a record or failure to disclose a document

_✓_ Potential failure to maintain/inspect/repair meters, sensors, and recording equipment

___ Potential failure to report regulated events, such as spills, accidents, etc.

2) If you observed deficiencies, did you communicate the deficiencies to the Facility during the inspection? **Yes / No**

3) Did you observe the Facility take any actions during the inspection to address the deficiencies noted? **Yes / No**

If yes, what actions were taken?

4) Did you provide general Compliance Assistance in accordance with the policy on the role of the EPA Inspector In providing Compliance Assistance during Inspections? **Yes / No**

5) Did you provide site-specific Compliance Assistance in accordance with the policy on the role of the EPA Inspector in providing Compliance Assistance during the inspection? **Yes / No**

Init/Date 2/1/13

Release Prevention Compliance Measures Matrix

Regulatory Subject Area	Measure #	SOC Measure / Federal Citation	In Compliance?		
			N/A	Y	N
I. Spill Prevention	1	Spill prevention device is present and functional. [280.20(c)(1)(i), 280.21(d)]		✓	
II. Overfill Prevention	2	Overfill prevention device is present and operational. [280.20(c)(1)(ii), 280.21(d)]		✓	
		✓ Automatic shutoff is operational (ie., device not tampered with or inoperable) [280.20(c)(1)(ii)(A), 280.21(d)] ❑ Alarm is operational. [280.20(c)(1) (ii)(B), 280.21(d)] ❑ Alarm is audible or visible to delivery driver. [280.20(c)(1) (ii)(B), 280.21(d)] ❑ Ball float is operational. [280.20(c)(1)(ii)(B), 280.21(d)]			
III a. Operation and Maintenance	3	Repaired tanks and piping were tightness tested within 30 days of repair completion (not required w/internal inspections or if monthly monitoring is in use). [280.33(d)]	✓		
III b. Operation and Maintenance of Corrosion Protection	4	CP systems were tested/inspected within 6 months of repair of any cathodically protected UST system. [280.33(e)]	✓		
	5	Corrosion protection system is properly operated and maintained to provide continuous protection. [280.31(a)(b), 280.70(a)]			✓
		❑ UST system (Choose one) ❑ UST in operation ❑ UST in temporary closure ❑ CP System is properly operated and maintained ❑ CP system is performing adequately based on results of testing. [280.31(b)]; - or - ❑ CP system tested within required period and operator is conducting or has completed appropriate repair in response to test results reflecting CP system not providing adequate protection.			

Release Prevention Compliance Measures Matrix

Regulatory Subject Area	Measure #	SOC Measure / Federal Citation	In Compliance?		
			N/A	Y	N
III b. Operation and Maintenance of Corrosion Protection (Continued)	6	UST systems with impressed current cathodic protection are inspected every 60 days. [280.31(c)]	✓		
	7	Lined tanks are inspected periodically and lining is in compliance. [280.21(b)(1)(ii)]	✓		
IV. Tank and Piping Corrosion Protection	8	Buried metal tank and piping (which includes fittings, connections, etc.) is corrosion protected. [280.20(a), 280.20(b), 280.21(b), 280.21(c)]			✓
		❑ Buried metal piping components (such as swing joints, flex-connector, etc.) are isolated from the soil or cathodically protected. For new USTs - tanks and piping installed after 12/22/88 [280.20(a), 280.20(b)]: ❑ Steel tank or piping is coated with suitable dielectric material and cathodically protected. [280.20(a)(2), 280.20(b)(2)] ❑ Tank is fiberglass, clad, or jacketed and piping is fiberglass or flexible plastic. [280.20(a)(1), 280.20(a)(3), 280.20(a)(5), 280.20(b)(1), 280.20(b)(4)] ❑ Records are available to document that CP is not necessary. [280.20(a)(4)(ii), 280.20(b)(3)(ii)] For existing USTs - tanks and piping installed on or before 12/22/88 [280.21(b), 280.21(c)]: ❑ Tank and piping meet new UST requirements [280.21(a)(1)] ❑ Steel tank is internally lined. [280.21 (b)] ❑ Metal tank and piping are cathodically protected. [280.21(b)(2), 280.21(c)]			

Notes: N/A - Indicates that the measure is not applicable.
Any mark in the "N" (No) column means that the facility is not in Significant Operational Compliance (SOC) with Release Prevention Compliance Measures. In order for a compliance measure to be in SOC, all applicable check-box items must be in compliance.

Release Detection Compliance Measures Matrix

Instructions - To Determine Compliance Status of Measures #1-7,
Work Through the Worksheet "Commonly Used Release Detection Methods" Below.

Regulatory Subject Area	Measure #	SOC Measure/ Federal Citation	In Compliance? N/A	Y	N
I. Release Detection Method Presence and Performance Requirements	1	Release detection method is present. [280.40(a)]			✓
	2	Release detection system is operating properly (i.e., able to detect a release from any portion of the system that routinely contains product). [(280.40(a)(1)]			✓
	3	Release detection system meets the performance standards at 280.43 or 280.44. [(280.40(a)(3)]			✓
	4	Implementing agency has been notified of suspected release as required. [(280.40(b)]	✓		
		☐ Non-passing results reported and resolved in accordance with implementing agency's directions. [280.40(b)]			
II. Release Detection Testing	5	Tanks and piping are monitored monthly for releases and records are available (must have records for the two most recent consecutive months and for 8 months of the last 12 months). [280.41(a), and 280.45(b)]			✓
III. Hazardous Substance UST Systems	6	Hazardous substance UST system leak detection meets the requirements (i.e., either secondarily contained or otherwise approved by the implementing agency). [280.42(b)]	✓		
IV. Temporary Closure	7	Release detection requirements are complied with (i.e., method present, operational, releases investigated and reported as required) for UST systems containing product. [280.70(a)]	✓		

Worksheet - Commonly Used Release Detection Methods

Tank (Choose one)	Pressurized Pipe (Choose Two)	Non-exempt Suction Pipe (Choose one)	Release Detection Method
☑ ✓		N/A Vent	**A. Inventory Control with Tank Tightness Testing (T.T.T)** ☐ Inventory control is conducted properly. ☐ T.T.T. performed as required (See "D" below). ☐ Inventory volume measurements for inputs, withdrawals, and remaining amounts are recorded each operating day and reconciled as required. [280.43(a)(1), 280.43(a)(3)] ☐ Equipment is capable of 1/8-inch measurement. [280.43(a)(2)] ☐ Product dispensing is metered and recorded within local standards for meter calibration to required accuracy. [280.43(a)(5)] ☐ Water is monitored at least monthly. [280.43(a)(6)]

Worksheet (Continued) - Commonly Used Release Detection Methods			
Tank (Choose one)	**Pressurized Pipe** (Choose Two)	**Non-exempt Suction Pipe** (Choose one)	**Release Detection Method**
❑			**B. Automatic Tank Gauge (ATG)** ❑ ATG is set up properly. [280.40(a)(2)] ❑ ATG can detect a 0.2 gal/hr leak rate from any portion of the tank routinely containing product. [280.43(d)(1)] ❑ ATG is checking portion of tank that routinely contains product. [280.40(a)(1)]
❑			**C. Manual Tank Gauging (MTG)** ❑ Tank size is appropriate for using MTG. [280.43(b)(5)] ❑ Tanks 1001 gals (as per EPA memo) and greater restricted to use with T.T.T. (See "D" below) ❑ Method is being conducted correctly. [280.43(b)(4)] ❑ No liquid was added to or taken out of the tank during the test. [280.43(b)(1)] ❑ Equipment is capable of 1/8-inch measurement. [280.43(b)(3)]
❑	❑	❑	**D. Tightness Testing** (Safe Suction piping does not require testing) ❑ Testing method is capable of detecting a 0.1 gal/hr leak rate from any portion of tank routinely containing product. [280.43(c)] ❑ Tightness testing is conducted within specified time frames for method: ❑ **Tanks** - every 5 years [280.41(a)(1)] ❑ **Pressurized Piping** - annually [280.41(b)(1)(ii)] ❑ **Non-exempt suction piping** - every 3 years [280.41(b)(2)] ❑ Tightness testing is conducted following manufacturer's instructions. [280.40(a)(3)]
❑	❑	❑	**E. Ground Water or Vapor Monitoring** ❑ Ground water in the monitoring well is never more than 20 feet from the ground surface. [280.43(f)(2)] ❑ Vapor monitoring well is not affected by high ground water. [280.43(e)(3)] ❑ Site assessment has been done for vapor or ground water monitoring. [280.43(e)(6), 280.43(f)(7)] ❑ Wells are properly designed and positioned. [280.43(e)(6), 280.43(f)(7)]
❑	❑	❑	**F. Interstitial Monitoring** ❑ Secondary containment can be used to detect a release [280.43(g)(1)], 280.43(g)(2)] ❑ Sensor properly positioned. [280.40(a)(2)]

Worksheet (Continued) - Commonly Used Release Detection Methods			
Tank (Choose one)	**Pressurized Pipe** (Choose Two)	**Non-exempt Suction Pipe** (Choose one)	**Release Detection Method**
	❑		**G. Automatic Line Leak Detector (ALLD)** ❑ ALLD is present and operational. [280.44(a)] ❑ Annual function test of the ALLD has been conducted and records are available. [280.44(a)]
❑	❑	❑	**H. Other Methods [e.g., Statistical Inventory Reconciliation (S.I.R.)]** ❑ The method can detect a 0.2 gal/hr leak rate or a release of 150 gal within a month and meet the 95/5 requirement [280.43(h)(1)]; or ❑ The implementing agency has approved the method as being as effective as tank tightness testing, automatic tank gauging, vapor monitoring, ground water monitoring, or interstitial monitoring and the operator complies with any conditions imposed by agency. [280.43(h)(2)] ❑ S.I.R. - Results are received within time frame established by implementing agency. [280.41(a) & 280.43(h)]

Notes: N/A - Indicates that the measure is not applicable.

Any mark in the "N" (No) column means that the facility is not in Significant Operational Compliance (SOC) with Release Detection Compliance Measures.

In order for a compliance measure to be in SOC, all applicable check-box items must be in compliance.